The School District of Palm Beach County Project Name SDPBC Project No.

# SECTION 33 34 14 ON-SITE EXTERIOR POLYETHYLENE GREASE TRAPS

#### PART 1 GENERAL

#### 1.1 WORK COVERED BY CONTRACT DOCUMENTS

- A. Furnish and install polyethylene grease traps as shown on the plans.
- B. Grease traps shall have no moving parts.

#### 1.2 REFERENCE DOCUMENTS

- A. ASME A112.14.3 Hydromechanical Grease Interceptors
- B. FBC Florida Building Code

### 1.3 SUBMITTALS

- A. Submit under provisions of Section 01 33 00.
- B. Prior to installation, the Contractor shall furnish to the Project Consultant the Manufacturer's standard data sheets describing components including materials, dimensions, relationship to adjacent construction, and attachments.
- C. Complete As-Built information and plans required before final acceptance of the system.
  - 1. Contractor shall provide accurate record of installed grease trap manhole rim elevations and inverts for the grease trap, influent pipe, and effluent pipe.
  - 2. Registered Surveyor shall provide all horizontal and vertical information in the Contractor's As-Built information.

#### 1.4 RELATED DOCUMENTS

A. Drawings and general provisions of Contract, including General and Supplementary Conditions and Division 1 specification sections, apply to work in this section.

### 1.5 WARRANTY

- A. Builders warranty shall be one year from the date of substantial completion.
- B. Manufacturer's warranty shall be lifetime in accordance with their written conditions.

### PART 2 PRODUCTS

## 2.1 MANUFACTURER

A. Hydromechanical grease interceptor as manufactured by Schier Products Company, Kansas City, Kansas, 66111.

## 2.2 FLOTATION

- A. Anchor unit to resist flotation assuming the unit is empty and ground water is at the top of the installed unit.
- B. Use manufacturer's anti-flotation anchor kit.

### PART 3 EXECUTION

- 3.1 Do not compact backfill.
- 3.2 Provide a 4" thick concrete slab at ground level above the grease trap.
- 3.3 Install unit within a protective concrete vault if the ground water level is expected to exceed the top of the installed unit.
- 3.4 Provide dead man anchors to go with the manufacturer's anti-flotation anchor kit.
- 3.5 Install in strict accordance with the manufacturer's requirements.

**END OF SECTION**