



**SCHOOL DISTRICT PALM BEACH COUNTY  
BUILDING DEPARTMENT  
CODE INTERPRETATION**

3661 Interstate Park Road North  
RIVIERA BEACH, FLORIDA 33404  
TEL (561) 688-7687 FAX (561) 882-1978

<http://www.palmbeachschools.org/buildingdepartment/Documents.asp>

Subject Title: Re-Signing Projects  
 Applicable Code: 2007 FBC Section 105 PERMITS  
 Date: March 8, 2011

**Question:**

When is a permit required for re-signing (room ID signs) projects and under what the requirements/conditions?

**Answer:**

Permits are required for any re-signage project which results in changing the room/rooms identification. Related work also requires a permit as follows:

- Sign installation
- Electrical panel labeling
- Fire alarm reprogramming
- Intercom system reprogramming

The matrix below identifies the requirements for the permits:

Permit Type	Application from	Drawing requirements	Inspections	Effective date
Sign Installation	Sign installer	Details on sign copy, installation and mounting heights and location plan	Final based on code an permit drawings	March 1, 2011
Electrical Panel Labeling	Outside contractor or district staff (FMC)	Revised panel schedules identifying affected rooms	Final of 10% - 20% of relabeling and 100% of new label system	March 1, 2011
Fire Alarm Reprogramming	Approved Fire Alarm Contractor	Schedule of rooms	Final of 100% of the system	Retroactive to include all projects within last 12 months
Intercom System Reprogramming	Outside contractor or district staff (FMC)	Schedule of rooms	Final of 100% of the system	Retroactive to include all projects within last 12 months

**Comment:**

- While the Building department is not permitting the Security or EMS system, the reprogramming of these two systems needs coordination with School Police and Environmental Control Office.
- See “Projects with Multiple Contractors” #BD-008 procedure for using the same project number with different contractors on the same project.